

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3175-1539:111 Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: Filtration Group, Inc., 912 E. Washington St., Joilet, IL 60433
Contact: *Joseph Benoit (815) 774-1289 Fax (815) 726-2765

DESIGN: Model Soni Q (SQ), Envopac S or EPS-95, S-85, S-65, S-50 and S-40 dry type, extended area, throw-away rigid air filters. Units utilize two types of synthetic media which are cut and ultrasonically sealed into the shape of bags or pockets. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Class 2

INSTALLATION: In accordance with listee's printed installation instructions, applicable does and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, size, direction of airflow and UL label.

APPROVAL: Listed as Class II throw-away air filter units.

NOTE: Formerly 3175-0960:108

*Rev. 06-21-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager